

**KEMA TYPE TEST CERTIFICATE OF COMPLETE TYPE TESTS**

**Object** Separable connector **1134-16**

**Type** WEB24-630 Tee Connector

Rated voltage, $U_0/U (U_m)$	12,7/22 (24) kV	Conductor material	Cu
Conductor cross-section	1x185 mm <sup>2</sup>	Insulation material	XLPE

**Manufacturer** Shenzhen Woer Heat-Shrinkable Material Co. Ltd.,  
Shenzhen, China

**Client** Shenzhen Woer Heat-Shrinkable Material Co. Ltd.,  
Shenzhen, China

**Tested by** KEMA Nederland B.V.,  
Arnhem, The Netherlands

**Date of tests** 8 July 2015 to 16 March 2016

The test object, constructed in accordance with the description, drawings and photographs incorporated in this certificate has been subjected to the series of proving tests in accordance with

**HD 629.1 S2 (2006)**

This Type Test Certificate has been issued by DNV GL following exclusively the STL Guides.


The results are shown in the record of Proving Tests and the oscillograms attached hereto. The values obtained and the general performance are considered to comply with the above Standard(s) and to justify the ratings assigned by the manufacturer as listed on page 5.

This Certificate applies only to the object tested. The responsibility for conformity of any object having the same type references as that tested rests with the Manufacturer.

<sup>\*)</sup> as declared by the manufacturer

This Certificate consists of 102 pages in total.

KEMA Nederland B.V.



J.P. Fonteijne  
Executive Vice President  
KEMA Laboratories



**Laboratories**

Arnhem, 22 April 2016

## TABLE OF CONTENTS

1	Identification of the object tested .....	5
1.1	Ratings/characteristics of the object tested	5
1.2	Description of the object tested	5
1.3	Characteristics of the cable used for testing (not part of the test object)	5
1.4	List of documents	7
2	General information.....	8
2.1	The tests were witnessed by	8
2.2	The tests were carried out by	8
2.3	Subcontracting	8
2.4	Measurement uncertainty	8
3	Test arrangement.....	9
3.1	Determination of the cable conductor temperature	9
3.2	Installation of separable screened connectors	9
3.3	Photographs of test set-up	10
4	Test sequence D1 (four samples) .....	12
4.1	DC voltage dry test	12
4.2	AC voltage dry test	13
4.3	Partial discharge test at ambient temperature	14
4.4	Impulse voltage test at elevated temperature	15
4.5	Heating cycle voltage test in air	18
4.6	Heating cycle voltage test in water	19
4.7	Disconnection / Connection	20
4.8	Partial discharge test at elevated temperature	21
4.9	Partial discharge test at ambient temperature	22
4.10	Impulse voltage at ambient temperature	23
4.11	AC voltage dry test	26
4.12	Examination	27
4.13	Photographs	28
5	Test sequence D2 (three samples) .....	30
5.1	DC voltage dry test	30
5.2	AC voltage dry test	31
5.3	Thermal short-circuit test (screen)	32
5.4	Thermal short-circuit test (conductor)	35
5.4.1	Legend	36
5.4.2	Test circuit S01	37
5.4.3	Photographs before test	38
5.4.4	Test results and oscillograms	45

5.4.5	Photographs after test	48
5.5	Dynamic short-circuit test (conductor)	51
5.5.1	Test circuit S02	52
5.5.2	Photograph before test	53
5.5.3	Test results and oscillograms	54
5.5.4	Photograph after test	56
5.6	Disconnection / Connection	57
5.7	Impulse voltage test at ambient temperature	58
5.8	AC voltage dry test	61
5.9	Additional thermal short-circuit test (screen)	62
5.9.1	Test circuit S03	63
5.9.2	Test results and oscillograms	64
5.10	Examination	67
5.11	Photographs	68
6	Screen resistance measurement.....	71
7	Leakage current measurement.....	72
8	Screen fault current initiation.....	73
8.1	Screen fault initiation – solidly earthed systems	73
8.2	Screen fault initiation – unearthed or impedance earthed systems	74
9	Drawings.....	75
10	Measurement uncertainty .....	78
Appendix A	Screen fault current initiation test.....	79

## 1 IDENTIFICATION OF THE OBJECT TESTED

### 1.1 Ratings/characteristics of the object tested

Rated voltage, $U_0/U$ ( $U_m$ )	12,7/22 (24) kV
Rated maximum conductor temperature in normal operation	90 °C
Rated conductor cross-section	1x185 mm <sup>2</sup>

The test voltages were based on  $U_0$  test = 12,7 kV.

### 1.2 Description of the object tested

Manufacturer	Shenzhen Woer Heat-Shrinkable Material Co. Ltd., Shenzhen, China
Type	WEB24-630 Tee Connector
Year of manufacture	2015
Rated voltage, $U_0/U$ ( $U_m$ )	12,7/22 (24) kV
No. of cores	1
Dynamic short-circuit current	100 kA
Type connector	Compressed cable lug, bolted to mating plug (no sliding contact)
Type of stress control	stress control cone
Capacitive test point	not applicable
Construction	see List of drawings

The object is not equipped with a capacitive test point.

### 1.3 Characteristics of the cable used for testing (not part of the test object)

Standard	IEC 60502-2, Clause 5-12
Manufacturer (as stated by the client)	Far East Cable Co. Ltd., Jiangsu, China
Type	$U_0 = 12$ kV 1x185 mm <sup>2</sup> XLPE CABLE (YJSV)
Manufacturing year	2014
Rated voltage, $U_0/U$ ( $U_m$ )	12/20 (24) kV
Overall diameter (D)	37,5 mm
Construction	see List of drawings

**Conductor**

- material copper
- cross-section 185 mm<sup>2</sup>
- nominal diameter (d) 16,1 mm
- type compacted stranded
- maximum conductor temperature in normal operation 90 °C
- presence and nature of measures to achieve longitudinal watertightness along insulation screen no

**Conductor screen**

- material semi-conducting PE
- nominal thickness 0,6 mm

**Insulation**

- material XLPE
- nominal thickness 5,5 mm
- nominal inner diameter of the insulation 17,3 mm
- nominal outer diameter of the insulation 28,3 mm

**Insulation (core) screen**

- material semi-conducting PE
- nominal thickness 0,6 mm

**Longitudinally watertightness**

- presence and nature of measures to achieve longitudinal watertightness along insulation screen no

**Metal screen**

- material copper wires
- number of wires 64
- nominal diameter of wires 1,0 mm
- number of tapes 1
- nominal thickness and width of tape 15 x 0,1 mm (open helix)

**Oversheath**

- material PVC type ST<sub>2</sub>
- nominal thickness 2,1 mm
- nominal overall diameter of the cable (D) 37,5 mm
- colour black
- graphite coating applied no

## 2 GENERAL INFORMATION

### 2.1 The tests were witnessed by

<b>Name</b>	<b>Company</b>
Mr Lei Yin	Shenzhen Woer Heat-Shrinkable Material Co. Ltd.,
Ms Lan Guo	Shenzhen, China
(24 August to 3 September 2015 and 20 January to 3 February 2016)	

### 2.2 The tests were carried out by

<b>Name</b>	<b>Company</b>
Mr Thomas Ariaans	KEMA Nederland B.V.,
Mr Chris Beverwijk	Arnhem, The Netherlands
Mr Marten Dekker	
Mr Francesco Ursino	

### 2.3 Subcontracting

The following test was subcontracted KEMA Laboratory ZKUŠEBNICTVÍ, a.s., Prague, Czech Republic:

- Screen fault current initiation test in accordance with table 7 test 19.

### 2.4 Measurement uncertainty

A table with measurement uncertainties is enclosed in this Certificate. Unless otherwise stated, the measurement uncertainties of the results presented in this Certificate are as indicated in that table.

## 3 TEST ARRANGEMENT

### 3.1 Determination of the cable conductor temperature

#### Standard

Standard IEC 61442, Subclause 8


For the tests at elevated temperature, a reference loop for temperature control of the conductor was installed and conductor current was used for heating. The reference cable was cut from the total cable length intended for the type test. This reference loop was installed close to the test loop in order to create the same environmental conditions as for the test loop.

The heating currents in the reference loop and the test loop were kept equal at all times, thus the conductor temperature of the reference loop is representative for the conductor temperature of the test loop. Annex A was used as a guide and Annex A, Subclause A.3.3, method 3 was applied.


The tests at elevated temperature were carried out after the conductor temperature was within the stated limit for at least 2 hours.

### 3.2 Installation of separable screened connectors

The installation of the separable connectors was in accordance with the client's specification as presented below.



### 3.3 Photographs of test set-up








Ver.: A0

## WEB24-630 Tee Connector and WEBK24-630 Rear Connector


### Installation Instruction

Each Connector Kit includes parts for one single-phase installation.



Tee Connector

- 1 - Tee Connector
- 1 - End Cap
- 1 - Cable Adapter
- 1 - Insulated Plug
- 1 - Two-headed Screw
- 1 - Lug
- 1 - Binding Wire
- 1 - Semi-conductive Tape
- 1 - Insulated Self-adhesive Tape
- 5 - Sealing Mastic
- 1 - Waterproof Tape
- 1 - PVC Tape
- 5 - Cleaning Paper
- 1 - Silicone Grease
- 1 - Abrasive Tape
- 1 - Nylon Belt
- 1 - Box Ruler
- 1 - Installation Tool
- 4 - PE Gloves
- 1 - Installation Instruction



Rear Connector

- 1 - Rear Connector
- 1 - Cable Adapter
- 1 - Connecting Pipe
- 1 - Two-headed Screw
- 1 - Lug
- 1 - Binding Wire
- 1 - Semi-conductive Tape
- 1 - Insulated Self-adhesive Tape
- 5 - Sealing Mastic
- 1 - Waterproof Tape
- 1 - PVC Tape
- 5 - Cleaning Paper
- 1 - Silicone Grease
- 1 - Abrasive Tape
- 1 - Nylon Belt
- 1 - Box Ruler
- 4 - PE Gloves
- 1 - Installation Instruction

#### Warning!

1. Before installation, please ensure all systems are de-energized and fully grounded!

2. The 630A bolted Tee connector system is designed to be operated in accordance with normal safe operating procedures. These instructions are not intended to supersede or replace existing safety and operating procedures. The Tee connector should be installed and serviced only by personnel familiar with the good safety practices and the handling of high-voltage electrical equipment.